



RFP No. 0918-20-GMHS-GS
George Mason High School Graphics & Signage

Date: September 17, 2020

ADDENDUM No. 3

To: **ALL PROSPECTIVE OFFERORS**

THIS ADDENDUM MUST BE SIGNED AND RETURNED WITH YOUR PROPOSAL.

THE SUBMISSION DATE HAS BEEN EXTENDED TO MONDAY, SEPTEMBER 21, 2020 AT 10:00AM.

REVISIONS TO ADDENDUM No. 1

Question 13 - Question 13 showed a blank 13.vi. There is no question 13.vi.

Question 34 - Question 34 showed a blank 34.c. There is no question 34.c.

Question 35 - revised for clarity as follows

35. Is the LEED Gold Logo for Sign Type 16 on Drawing A6- 401 to be done via standard direct to substrate digital printing? **Yes**

a. Will artwork for this logo be provided? **Yes**

Question 37 - revised for clarity as follows

37. Is the construction intent for Sign Type 19 on Drawing A6- 401 to be a digital print on vinyl applied to mill finish aluminum or direct printed graphics onto painted aluminum?

Digital print on vinyl applied to mill finish aluminum

a. What thickness aluminum is to be quoted? **The thickness should be 0.080 inches.**

b. What type of mounting is required for this sign type (d/f tape and silicone or temper resistant screws through the face)? **See response to question 8 on Addendum 1.**

QUESTIONS (Questions shown in Black and Answers in Blue)

1. Does an Offeror need to have a City BPOL in order to submit a proposal?

No

2. Regarding the promenade letters, whether the eyebrow bar is existing or if this is to be part of the letters/signage we are to provide?

The eyebrow bar is part of the base building construction. The signage contractor will need to attach to it, but not furnish or install it.

3. Regarding the café blade sign, can we supply an alternate?

No, alternates are not acceptable. As stated in Addendum 1, response to Question 39.a.: "Vendors should carry a cost for a spec of similar cost to the SW 7076." A complete alternative to the sign itself is not acceptable, or requested.

4. Regarding the large letter for the restroom signs, can we supply an alternate?

No alternates are acceptable or requested.

5. For the exterior halo illuminated letters, what is the interior conditions and will there be electrical run to the location for each letter? Any special conditions we should be aware of?

Electrical feed will be run to a junction box, at a central location behind the letter bar. Power for each letter will need to be connected to this central point by signage contractor.

6. For the wall graphics, we don't know of any material that is graffiti resistant. Can we supply our standard Traffic or Conform that is UV resistant?

Reference response to Question 16 in Addendum 1.

7. Page 21 of the design intent: Are the Glass Panels part of the scope

Previous Answer: Yes

Follow-Up Question: If the sign company is to provide the glass does the architect know how they would like glass affixed on top of the graphic? Can we digitally print the graphics onto the back of water clear acrylic and then affix to the wall?

Glass is to be placed in front of graphic by a 1/4" standoff. Clear acrylic is not acceptable.

8. Page 25-27: Will the glass be provided by the GC or another vendor?

Glass windows will be in place for graphics to be applied to.

9. (Note: Originally Question 34 on Addendum No. 1, answer inadvertently omitted)
May we quote Sign Type 15 on Drawing A6- 401 as reflective red vinyl applied to the face of mill finish aluminum with applied white vinyl graphics?

Yes

10. *(Note: Originally Question 36 on Addendum No. 1, answer inadvertently omitted)*
What thickness acrylic is to be quote for Sign Type 18 on Drawing A6- 401?

0.125"

ALL OTHER TERMS AND CONDITIONS REMAIN UNCHANGED AND IN FULL FORCE & EFFECT.

Contractor must take due notice and be governed accordingly. This Addendum is considered a part of the above referenced solicitation.

Acknowledged by:

Name of Firm

Authorized Signature

Date